

# Safety Data Sheet

according to Regulation (EC) No. 1907/2006 (REACH) with its amendment Regulation (EU) 2015/830

## Propane 95+

Date of issue: 18/05/2016

Supersedes: 18/05/2016

Revision date: 26/05/2017

Version: 2.0

SDS reference: LAT-C3H8-C4H10-095

**Danger**



### SECTION 1: Identification of the substance/mixture and of the company/undertaking

#### 1.1. Product identifier

Trade name : Propane 95+

SDS no : LAT-C3H8-C4H10-095

#### 1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use.  
Test gas/Calibration gas.  
Laboratory use.  
Contact supplier for more information on uses.

Uses advised against : Consumer use.

#### 1.3. Details of the supplier of the safety data sheet

Company identification : Elme Messer L  
Katlakalna iela 9  
LV-1073 Rīga Latvija  
00371 67355445  
www.elmemesser.lv  
eml@eml.lv

#### 1.4. Emergency telephone number

Emergency telephone number : 112 (24h) Elme Messer L +371 67355445

### SECTION 2: Hazards identification

#### 2.1. Classification of the substance or mixture

##### Classification according to Regulation (EC) No. 1272/2008 [CLP]

Physical hazards	Flam. Gas 1	H220	Calculation method
	Press. Gas (Liq.)	H280	Calculation method

Full text of H-statements see section 16.

#### 2.2. Label elements

##### Labelling according to Regulation (EC) No. 1272/2008 [CLP]

Hazard pictograms (CLP) :



GHS02

GHS04

Signal word (CLP) : Danger

Hazard statements (CLP) : H220 - Extremely flammable gas.  
H280 - Contains gas under pressure; may explode if heated.

Precautionary statements (CLP)

- Prevention : P210 - Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No

- smoking.
- Response : P377 - Leaking gas fire: Do not extinguish, unless leak can be stopped safely.  
P381 - In case of leakage, eliminate all ignition sources.
  - Storage : P403 - Store in a well-ventilated place.

**2.3. Other hazards**

: None.

**SECTION 3: Composition/information on ingredients**

**3.1. Substances** : Not applicable

**3.2. Mixtures**

Name	Product identifier	%	Classification according to Regulation (EC) No. 1272/2008 [CLP]
Propane	(CAS-No.) 74-98-6 (EC-No.) 200-827-9 (EC Index-No.) 601-003-00-5 (REACH-no) 01-2119486944-21	>= 95	Flam. Gas 1, H220 Press. Gas (Liq.), H280
Butane n-	(CAS-No.) 106-97-8 (EC-No.) 203-448-7 (EC Index-No.) 601-004-00-0 (REACH-no) 01-2119474691-32	balance	Flam. Gas 1, H220 Press. Gas (Liq.), H280

**SECTION 4: First aid measures**

**4.1. Description of first aid measures**

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep victim warm and rested. Call a doctor. Perform cardiopulmonary resuscitation if breathing stopped.
- Skin contact : For liquid spillage - flush with water for at least 15 minutes.
- Eye contact : Immediately flush eyes thoroughly with water for at least 15 minutes.
- Ingestion : Ingestion is not considered a potential route of exposure.

**4.2. Most important symptoms and effects, both acute and delayed**

: In high concentrations may cause asphyxiation. Symptoms may include loss of mobility/consciousness. Victim may not be aware of asphyxiation.  
Refer to section 11.

**4.3. Indication of any immediate medical attention and special treatment needed**

: None.

**SECTION 5: Firefighting measures**

**5.1. Extinguishing media**

- Suitable extinguishing media : Water spray or fog.
- Unsuitable extinguishing media : Carbon dioxide.  
Do not use water jet to extinguish.

**5.2. Special hazards arising from the substance or mixture**

Specific hazards : Exposure to fire may cause containers to rupture/explode.

Hazardous combustion products : Incomplete combustion may form carbon monoxide.

**5.3. Advice for firefighters**

Specific methods : Use fire control measures appropriate for the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering sewers and drainage systems.  
If possible, stop flow of product.  
Use water spray or fog to knock down fire fumes if possible.  
Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive re-ignition may occur. Extinguish any other fire.  
Move containers away from the fire area if this can be done without risk.

Special protective equipment for fire fighters : In confined space use self-contained breathing apparatus.  
Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire fighters.  
Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full face mask.  
Standard EN 469 - Protective clothing for firefighters. Standard - EN 659: Protective gloves for firefighters.

**SECTION 6: Accidental release measures**

**6.1. Personal precautions, protective equipment and emergency procedures**

: Try to stop release.  
Evacuate area.  
Consider the risk of potentially explosive atmospheres.  
Eliminate ignition sources.  
Ensure adequate air ventilation.  
Prevent from entering sewers, basements and workpits, or any place where its accumulation can be dangerous.  
Act in accordance with local emergency plan.  
Stay upwind.

**6.2. Environmental precautions**

: Try to stop release.

**6.3. Methods and material for containment and cleaning up**

: Ventilate area.

**6.4. Reference to other sections**

: See also sections 8 and 13.

**SECTION 7: Handling and storage**

**7.1. Precautions for safe handling**

Safe use of the product : Do not smoke while handling product.  
Assess the risk of potentially explosive atmospheres and the need for explosion-proof equipment.  
Purge air from system before introducing gas.  
Take precautionary measures against static discharge.  
Keep away from ignition sources (including static discharges).  
Consider the use of only non-sparking tools.  
The product must be handled in accordance with good industrial hygiene and safety procedures.  
Only experienced and properly instructed persons should handle gases under pressure.  
Consider pressure relief device(s) in gas installations.  
Ensure the complete gas system was (or is regularly) checked for leaks before use.  
Protect eyes, face and skin from liquid splashes.  
Use only properly specified equipment which is suitable for this product, its supply pressure and temperature. Contact your gas supplier if in doubt.  
Do not breathe gas.  
Avoid release of product into atmosphere.

Safe handling of the gas receptacle : Refer to supplier's container handling instructions.  
 Do not allow backfeed into the container.  
 Protect cylinders from physical damage; do not drag, roll, slide or drop.  
 When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders.  
 Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use.  
 If user experiences any difficulty operating cylinder valve discontinue use and contact supplier.  
 Never attempt to repair or modify container valves or safety relief devices.  
 Damaged valves should be reported immediately to the supplier.  
 Keep container valve outlets clean and free from contaminants particularly oil and water.  
 Replace valve outlet caps or plugs and container caps where supplied as soon as container is disconnected from equipment.  
 Close container valve after each use and when empty, even if still connected to equipment.  
 Never attempt to transfer gases from one cylinder/container to another.  
 Never use direct flame or electrical heating devices to raise the pressure of a container.  
 Do not remove or deface labels provided by the supplier for the identification of the cylinder contents.  
 Containers should be stored in the vertical position and properly secured to prevent them from falling over.

**7.2. Conditions for safe storage, including any incompatibilities**

: Observe all regulations and local requirements regarding storage of containers.  
 Containers should not be stored in conditions likely to encourage corrosion.  
 Container valve guards or caps should be in place.  
 Containers should be stored in the vertical position and properly secured to prevent them from falling over.  
 Stored containers should be periodically checked for general condition and leakage.  
 Keep container below 50°C in a well ventilated place.  
 Store containers in location free from fire risk and away from sources of heat and ignition.  
 Keep away from combustible materials.  
 Segregate from oxidant gases and other oxidants in store.  
 All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.

**7.3. Specific end use(s)**

: None.

**SECTION 8: Exposure controls/personal protection**

**8.1. Control parameters**

<b>Butane n- (106-97-8)</b>		
OEL : Occupational Exposure Limits		
Latvia	TWA (LV) OEL 8h [mg/m³]	300 mg/m³

DNEL (Derived-No Effect Level) : No data available.

PNEC (Predicted No-Effect Concentration) : No data available.

**8.2. Exposure controls**

**8.2.1. Appropriate engineering controls**

: Provide adequate general and local exhaust ventilation.  
 Systems under pressure should be regularly checked for leakages.  
 Ensure exposure is below occupational exposure limits (where available).  
 Keep concentrations well below lower explosion limits.  
 Gas detectors should be used when flammable gases/vapours may be released.  
 Consider the use of a work permit system e.g. for maintenance activities.

**8.2.2. Individual protection measures, e.g. personal protective equipment**

: A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk. The following recommendations should be considered:  
 PPE compliant to the recommended EN/ISO standards should be selected.

- Eye/face protection : Wear safety glasses with side shields.  
Wear goggles and a face shield when transfilling or breaking transfer connections.  
Standard EN 166 - Personal eye-protection - specifications
- Skin protection
  - Hand protection : Wear working gloves when handling gas containers.  
Standard EN 388 - Protective gloves against mechanical risk.
  - Other : Consider the use of flame resistant anti-static safety clothing.  
Standard EN ISO 14116 - Limited flame spread materials.  
Standard EN ISO 1149-5 - Protective clothing: Electrostatic properties.  
Wear safety shoes while handling containers.  
Standard EN ISO 20345 - Personal protective equipment - Safety footwear.
- Respiratory protection : Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be used in oxygen-deficient atmospheres.  
Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full face mask.
- Thermal hazards : Wear cold insulating gloves when transfilling or breaking transfer connections.  
Standard EN 511 - Cold insulating gloves.

**8.2.3. Environmental exposure controls**

- : Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for specific methods for waste gas treatment.

**SECTION 9: Physical and chemical properties**

**9.1. Information on basic physical and chemical properties**

Appearance

- Physical state at 20°C / 101.3kPa : Gas.
- Colour : Mixture contains one or more component(s) which have the following colour(s):  
Colourless.

Odour : There may be no odour warning properties, odour is subjective and inadequate to warn of overexposure.

Mixture contains one or more component(s) which have the following odour(s):  
Stenchant often added. Sweetish.

Odour threshold : Odour threshold is subjective and inadequate to warn of overexposure.

pH value : Not applicable for gas mixtures.

Molar mass : Not applicable for gas mixtures.

Melting point : Not applicable for gas mixtures.

Boiling point : Not applicable for gas mixtures.

Flash point : Not applicable for gas mixtures.

Evaporation rate (ether=1) : Not applicable for gas mixtures.

Flammability range : Flammability range not available.

Vapour pressure [20°C] : No reliable data available.

Vapour pressure [50°C] : No reliable data available.

Relative density, gas (air=1) : Heavier than air.

Solubility in water : No data available

Partition coefficient n-octanol/water [log Kow] : Not applicable for gas mixtures.

Auto-ignition temperature : Not known.

Viscosity [20°C] : Not applicable.

Explosive Properties : Not applicable.

Oxidising Properties : Not applicable.

**9.2. Other information**

Other data : Gas/vapour heavier than air. May accumulate in confined spaces, particularly at or below ground level.

**SECTION 10: Stability and reactivity**

**10.1. Reactivity**

: No reactivity hazard other than the effects described in sub-sections below.

**10.2. Chemical stability**

: Stable under normal conditions.

**10.3. Possibility of hazardous reactions**

: May react violently with oxidants.  
Can form explosive mixture with air.

**10.4. Conditions to avoid**

: Keep away from heat/sparks/open flames/hot surfaces. – No smoking.

**10.5. Incompatible materials**

: Air, Oxidisers.  
For additional information on compatibility refer to ISO 11114.

**10.6. Hazardous decomposition products**

: Under normal conditions of storage and use, hazardous decomposition products should not be produced.

**SECTION 11: Toxicological information**

**11.1. Information on toxicological effects**

**Acute toxicity** : Classification criteria are not met.  
Toxicological effects not expected from this product if occupational exposure limit values are not exceeded.

**Propane (74-98-6)**

LC50 inhalation rat (ppm)	20000 ppm/4h
---------------------------	--------------

**Skin corrosion/irritation** : No known effects from this product.  
**Serious eye damage/irritation** : No known effects from this product.  
**Respiratory or skin sensitisation** : No known effects from this product.  
**Germ cell mutagenicity** : No known effects from this product.  
**Carcinogenicity** : No known effects from this product.  
**Toxic for reproduction : Fertility** : No known effects from this product.  
**Toxic for reproduction : unborn child** : No known effects from this product.  
**STOT-single exposure** : No known effects from this product.  
**STOT-repeated exposure** : No known effects from this product.  
**Aspiration hazard** : Not applicable for gases and gas mixtures.

**SECTION 12: Ecological information**

**12.1. Toxicity**

Assessment : Classification criteria are not met.

**12.2. Persistence and degradability**

Assessment : No data available.

**12.3. Bioaccumulative potential**

Assessment : No data available.

**12.4. Mobility in soil**

Assessment : No data available.

**12.5. Results of PBT and vPvB assessment**

Assessment : Not classified as PBT or vPvB.

**12.6. Other adverse effects**

Effect on the ozone layer : None.

Effect on global warming : Contains greenhouse gas(es).

**SECTION 13: Disposal considerations**

**13.1. Waste treatment methods**

Contact supplier if guidance is required.  
 Do not discharge into areas where there is a risk of forming an explosive mixture with air.  
 Waste gas should be flared through a suitable burner with flash back arrestor.  
 Do not discharge into any place where its accumulation could be dangerous.  
 Ensure that the emission levels from local regulations or operating permits are not exceeded.  
 Refer to the EIGA code of practice Doc.30 "Disposal of Gases", downloadable at <http://www.eiga.org> for more guidance on suitable disposal methods.

List of hazardous waste codes (from Commission Decision 2001/118/EC) : 16 05 04 \*: Gases in pressure containers (including halons) containing dangerous substances.

**13.2. Additional information**

: None.

**SECTION 14: Transport information**

**14.1. UN number**

UN-No. : 1965

**14.2. UN proper shipping name**

**Transport by road/rail (ADR/RID)** : HYDROCARBON GAS MIXTURE, LIQUEFIED, N.O.S. (Propane, Butane n-)

**Transport by air (ICAO-TI / IATA-DGR)** : Hydrocarbon gas mixture, liquefied, n.o.s. (Propane, Butane n-)

**Transport by sea (IMDG)** : HYDROCARBON GAS MIXTURE, LIQUEFIED, N.O.S. (Propane, Butane n-)

**14.3. Transport hazard class(es)**

**Labelling** :



2.1 : Flammable gases

**Transport by road/rail (ADR/RID)**

Class : 2

Classification code : 2F

Hazard identification number : 23

Tunnel Restriction : B/D - Tank carriage : Passage forbidden through tunnels of category B, C, D and E. Other carriage : Passage forbidden through tunnels of category D and E

**Transport by air (ICAO-TI / IATA-DGR)**

Class / Div. (Sub. risk(s)) : 2.1

**Transport by sea (IMDG)**

Class / Div. (Sub. risk(s)) : 2.1

Emergency Schedule (EmS) - Fire : F-D

Emergency Schedule (EmS) - Spillage : S-U

**14.4. Packing group**

Transport by road/rail (ADR/RID) : Not applicable

Transport by air (ICAO-TI / IATA-DGR) : Not applicable

Transport by sea (IMDG) : Not applicable

**14.5. Environmental hazards**

Transport by road/rail (ADR/RID) : None.

Transport by air (ICAO-TI / IATA-DGR) : None.

Transport by sea (IMDG) : None.

**14.6. Special precautions for user**

**Packing Instruction(s)**

Transport by road/rail (ADR/RID) : P200

Transport by air (ICAO-TI / IATA-DGR)

    Passenger and Cargo Aircraft : Forbidden

    Cargo Aircraft only : 200

Transport by sea (IMDG) : P200

Special transport precautions : Avoid transport on vehicles where the load space is not separated from the driver's compartment.  
 Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or an emergency.  
 Before transporting product containers:  
 - Ensure there is adequate ventilation.  
 - Ensure that containers are firmly secured.  
 - Ensure cylinder valve is closed and not leaking.  
 - Ensure valve outlet cap nut or plug (where provided) is correctly fitted.  
 - Ensure valve protection device (where provided) is correctly fitted.

**14.7. Transport in bulk according to Annex II of Marpol and the IBC Code**

: Not applicable.

**SECTION 15: Regulatory information**

**15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture**

**EU-Regulations**

Seveso Directive : 2012/18/EU (Seveso III) : Covered.

**National regulations**

National legislation : Ensure all national/local regulations are observed.

Water hazard class (WGK) : -

**15.2. Chemical safety assessment**



: A CSA does not need to be carried out for this product.

**SECTION 16: Other information**

Indication of changes : Revised safety data sheet in accordance with commission regulation (EU) No 2015/830.  
 Training advice : Ensure operators understand the flammability hazard. Receptacle under pressure.  
 Further information : This Safety Data Sheet has been established in accordance with the applicable European Union legislation. Classification in accordance with the calculation methods of Regulation (EC) 1272/2008 CLP.

Full text of H- and EUH-statements

Flam. Gas 1	Flammable gases, Category 1
Press. Gas (Liq.)	Gases under pressure : Liquefied gas
H220	Extremely flammable gas
H280	Contains gas under pressure; may explode if heated

DISCLAIMER OF LIABILITY : Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out.  
 Details given in this document are believed to be correct at the time of going to press.  
 Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.

**End of document**